

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1501:105 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Edwards, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Dave Mazur (203) 699-3155

DESIGN: Models 2440S-15-R, -15-W, -15/75-R, -15/75-W, -30-R, -30-W, -60-R, -60-W, -110-R, -110-W, 110R-N5, -110W-N5; Models 2441S-15-R, -15-W, 15/75-R, 15/75-W, -30-R, -30-W, -60-R, -60-W, -110-R, -110-W strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: -15:15cd
-30: 30cd
-60: 60 cd
-15/75: 15/75cd
-110: 110cd

Electrical: 20-24 VDC except for Model 2440S-110R-N5 and -110W-N5 are 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name model number, candela/electrical rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible control units. Suitable for the hearing impaired application. For indoor use only.

XLf: 7125-1388:208

12-23-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager